



FORTIFIED Asphalt Shingle Re-Roof Requirements

INFO@FORTIFIEDPRO.COM
(251) 386-2230 | (504) 289-1367

MATERIAL PHOTOS

- 1 - Label on .113, 2 3/8" Ring Shank Nails Box
- 1 - Underlayment Label
- 1 - Roof Deck Tape Packaging (when applicable)
- 1 - Roof Vent Packaging
- 1 - Low Slope Roofing Material Packaging
- 1 - Backside of Shingle Package/Wind Label
- 1 - Self Adhered Starter Strip Packaging

We will also accept invoices showing delivery to site address for material photos.

RE-ROOF PROCESS PHOTOS

- 4 - Roof Deck Nailing with **measuring tape 4'**

At least 2 pictures of any low slope portions

- 4 - Installed Underlayment
- 4 - Roof Deck Tape (when applicable)
- 4 - Showing Underlayment Fastener Spacing with Measuring Tape
- 4 - Drip Edge Nail Pattern

Drip edge always goes on top of the underlayment

- 4 - Installed Starter Strips
- 4 - Showing all 4 Elevations of Final Installed Roof Cover
- 1 - Showing all Installed Roof Vents
- 1 - For Each Gable Showing Removable Cover Installed or Permanently Closed

HIGH WIND *Risk Cat. 2. V-Ult 115 mph or lower*

- **6"** roof deck nail spacing with 2 3/8" 8d Ring Shank nails
OR 4" roof deck nail spacing - with 2 1/2" 8d Common nails
 - 12d 3" nail required when over decking.
- 12" drip edge nail spacing
- Drip edge always goes on top of the underlayment!!
- 15/32" is the minimum required thickness when replacing a broken or rotted deck boards for IRC2021 & IRC2018 (7/16" for IRC2015 & IRC2012).
- If the minimum allowed 7/16" roof deck thickness isn't present, over-decking is required. Exception: 3/8" roof deck thickness is only allowed with 16" rafter spacing.
- For dimensional lumber T&G and Shiplap are typically ok but straight boards with gaps well over 1/8" will require over-decking.

HURRICANE *Risk Cat. 2 V-Uly 116 mph or greater*

- 4" roof deck nail spacing - 2 3/8" Ring shank nails
 - 12d 3" Ring Shank required when over decking
- 4" drip edge nail spacing
- Drip edge always goes on top of the underlayment!
- 15/32" is the minimum required thickness when replacing a broken or rotted deck boards for IRC2021 & IRC2018 (7/16" for IRC2015 & IRC2012).
- If the minimum allowed 7/16" roof deck thickness isn't present, over-decking is required.No Exception For Hurricane Region
- For dimensional lumber T&G and Shiplap are typically ok but straight boards with gaps well over 1/8" will require over-decking.

Last updated 3/2/2025